

Section 1001.3 “Plans,” of the UFC is amended to read as follows:

Voltage of the fire alarm panel or the power expansion panel.

13.04.185 Inspection and Testing.

Section 1001.5.2 “Inspection and Testing,” of the UFC is amended by adding two new subsections to read as follows:

1001.5.2 Inspection and Testing.

1001.5.2.1 Private Fire Hydrants. All private fire hydrant systems shall be serviced to the satisfaction of the Fire Department on a yearly basis. Service records shall be kept on-site and shall be readily available to the inspection authority. A copy of said service record shall be mailed within 48 hours, to the Fire Prevention Bureau when any deficiency of the system or violation of the Fire Code is noted.

1001.5.2.2 Fire Protection Systems. All Fire Protection Systems shall be inspected and tested in accordance with the provisions of the Nevada State Fire Marshal's Regulations. A copy of said inspection shall be mailed within 48 hours, to the Fire Prevention Bureau only when any deficiency of the system or violation of the Fire Code is noted. In the event a service/maintenance contract is canceled or not renewed, the Fire Prevention Bureau shall be notified by the service company within 24 hours.

13.04.190 Problematic Systems and Systems Out of Service.

Section 1001.5.3.1 “Problematic systems and systems out of service,” of the UFC is amended and a new second paragraph is added to read as follows:

1001.5.3.1 Problematic Systems and Systems Out of Service. In the event of a failure of a fire protection system or an excessive number of false or nuisance alarm activations, the Chief is authorized to require the building owner or occupant to provide fire watch personnel until the